

forecasted growth increase, all three 345 kV Projects are needed to maintain regional reliability.

Forecast Source	Forecast Scenario	Load Forecast		Load Growth by 2020 (MW)
		2009	2020	
CapX2020 Vision Plan	Expected Growth	20,201	26,488	6,287
	Slow Growth	20,201	24,701	4,500
Integrated Resource Plans	High	22,488	27,392	4,904
	Median	21,332	25,427	4,095
MAPP Load and Capability Data	System Demand	20,783	25,969	5,186

Response By: Amanda King
 Title: Sr. Transmission Planning Engineer
 Department: Transmission Planning
 Company: Xcel Energy
 Telephone: 612-330-5931
 Date: May 14, 2008

Response By: Daniel Kline
 Title: Transmission Planning Engineer
 Department: Transmission Reliability & Assessment
 Company: Xcel Energy
 Telephone: 612-330-7547
 Date: May 14, 2008

Response By: Jared Alholinna
 Title: Senior Transmission Planning Engineer
 Department: Transmission Planning, Contracts & Strategy
 Company: Great River Energy

Telephone: 763-445-5960

Date: May 14, 2008

Response By: Matt Lacey

Title: Regulatory Policy Analyst

Department: Transmission

Company: Great River Energy

Telephone: 763-445-5958

Date: May 14, 2008

2172777v1